



- NOTES:
1. ENCLOSURE MUST MEET OSHA 29 CFR 1910.146 AND ASSE 1060
 2. ALL ENCLOSURES INCLUDE A THERMOSTATICALLY-CONTROLLED ELECTRIC POWERED HEATER WITH A GFI.
 3. ENCLOSURE MUST BE A SUFFICIENT SIZE TO HOUSE ALL REQUIRED PIPING.
 4. ENCLOSURE MUST BE LOCKABLE.

DO NOT SCALE - USE DIMENSIONS ONLY

ENCLOSURE DETAIL

AKRON WATER SUPPLY BUREAU STANDARD DRAWINGS FOUND ONLINE AT
<http://www.akronohio.gov/water>

CITY OF AKRON
 DEPARTMENT OF PUBLIC SERVICE
 WATER SUPPLY BUREAU

METER AND BACKFLOW PREVENTER
 ABOVE GROUND HEATED ENCLOSURE

REV. DECEMBER 13, 2023

RALD
 UTILITIES ENGINEER

STANDARD CONSTRUCTION
 DRAWING NO. **M-10.0**