



NOTE

THE AKRON WATER SUPPLY BUREAU (AWSB) SUGGESTS A FLOOR PLAN THAT IS DESIGNED WITH THE WATER ENTRY POINT LOCATED IN A ROOM WITH AN EXTERIOR WALL, SO THE METER TRANSMITTER CAN BE EASILY LOCATED ON THE EXTERIOR OF THE STRUCTURE. OTHERWISE, METER TRANSMITTER WIRING CONDUIT MUST BE INSTALLED BY THE CONTRACTOR THROUGH WALLS OR CEILINGS TO ACCOMMODATE THE INSTALLATION OF THE REQUIRED METER TRANSMITTER WIRING.

DO NOT SCALE - USE DIMENSIONS ONLY

CITY OF AKRON
DEPARTMENT OF PUBLIC SERVICE
WATER SUPPLY BUREAU

INTERIOR METER SETTING

REV. APRIL 10, 2024

AKRON WATER SUPPLY BUREAU STANDARD DRAWINGS FOUND ONLINE AT
<http://www.akronohio.gov/water>

TRAJLO
UTILITIES ENGINEER

STANDARD CONSTRUCTION
DRAWING NO.

S-7.0