

**CITY OF AKRON, OHIO
DEPARTMENT OF PUBLIC SERVICE
WATER SUPPLY BUREAU**

SPECIFICATIONS FOR COPPER TUBING

GENERAL

Furnish extra soft type K seamless copper service tubing for underground conforming to the latest revision of the ANSI/AWWA C800, Section A.2 and ASTM B-88 specifications. Sizes of copper tubing quoted on the order represent nominal diameters.

Material shall be shipped in coils, clean, free of dirt and defects of a nature that would interfere with the normal waterworks application of the copper tubing.

The copper tubing must be free of cuprous oxide when inspected by a microscopic magnification of 75 diameters. Certification of such inspection must be provided upon request.

SPECIAL INSTRUCTIONS

Specify the manufacturer of the copper tubing proposed to be furnished.