

**CITY OF AKRON, OHIO
DEPARTMENT OF PUBLIC SERVICE
WATER SUPPLY BUREAU**

SPECIFICATIONS FOR VALVE BOXES

DESCRIPTION

All valve boxes shall be of best quality cast iron and workmanship and shall conform in all respects to the dimensions and requirements of on Akron Water Supply Bureau Standard Construction Drawing W-6.0 Standard Valve Box. All parts shall be interchangeable with boxes in use in the City of Akron.

Acceptable brands of valve boxes in use, with compatible parts are:

Bibby
Union/Tyler
EJIW
Star (heavy duty style only)

Each part shall weigh not less than twenty (20) percent or exceed twenty (20) percent of the weight stated on Standard Construction Drawing W-6.0.

Upon request prior to the award, bidders will be required to submit in a timely manner for evaluation sample valve box parts representative of the model and quality they intend to furnish.

INSTRUCTIONS TO BIDDERS

Each bidder shall provide drawings describing the valve boxes they propose to furnish.