



Village of Arlington Heights
Building & Life Safety Department
847-368-5560
www.vah.com

Sewer Repair/Clean Out Acknowledgment

- ✓ Sewer service passing through or under foundation wall shall meet the requirements of the Illinois State Plumbing Code 2014, Section 890.1150A (2).
- ✓ The building drain shall extend a minimum of 5" outside of foundation wall.
- ✓ The building sewer shall be SDR-26 with SDR-26 fitting. Section 890.1150A (1).
- ✓ All sewer services passing over water service/water main shall meet or exceed the Illinois State Plumbing Code requirements. Section 890.1150B (1, 2, 3).
- ✓ All connections between dissimilar piping shall be made with non-shear couplings.
- ✓ All sewer clean outs shall be at grade elevation.
- ✓ Coring machine shall be used for new sewer connection to main sewer.
- ✓ **If sewer repair is within 10 feet of water line PVC Schedule 40 solvent joints are required. Section 890.1150A (2).**

The undersigned has read and understands the information provided in this informational handout, and agrees to comply with all applicable Village codes.

Date: _____

Signature: _____

Print Name: _____

Job-Site Address: _____