



City of Enterprise

Department of Engineering Services & Public Works

501 S Main Street

Enterprise, Alabama 36330

Phone (334) 348-2671

Fax (334) 348-2672

Business Walk Through Requirements

- Site address shall be visible from the street.
- All outside entrances and exits shall be illuminated by an outside light source.
- Emergency lighting is required. Illuminated exit signs and lighting shall produce enough light from a battery backup to allow all persons to safely exit the building in the case of a power outage.
- A clear path of entrance and exit shall be required inside and outside the building.
- The emergency exit door should have a lever handle or panic hardware; no door knobs.
- All electrical breakers shall be properly installed with no openings and shall be clearly labeled.
- All necessary outlets shall be GFCI; that is, any outlets within 6 feet of a water source or as required by code.
- A mounted 2-A: 10-B:C Certified Fire extinguisher shall be within 75 feet of each entrance and exit.
- The fire and smoke alarms and the fire suppression system shall be checked on hotels, motels, and apartment complex units.
- Fire suppression systems or hood vent fire suppression systems shall be required to have the annual servicing date clearly labeled.
- Special cases may require more inspections.