

**Pleasant Grove City**  
**Annual Drinking Water Quality Report**  
**2023**

We are pleased to present to you this year's Annual Drinking Water Quality Report. This report is designed to inform you about the quality of the water we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water distribution system and protect our water resources. We are committed to ensuring your water is high quality.

**We are pleased to report that our drinking water meets all Federal and Utah State requirements.**

Our culinary water sources consist of eight springs and six wells. The Drinking Water Source Protection Plan for Pleasant Grove City contains information about source protection zones, potential contamination sources and management strategies to protect our drinking water. Our sources are located in protected areas and have a low level of susceptibility to potential contamination. We have developed management strategies to further protect our sources. The Drinking Water Source Protection Plan for Pleasant Grove City is available for your review. Please contact us if you have questions or concerns about our source protection plan.

There are many connections to our culinary water distribution system. When connections are properly installed and maintained the concerns are very minimal. Unapproved and improper piping changes or connections can adversely affect not only the availability, but also the quality of the water. A cross-connection may let polluted water or unwanted chemicals enter the water distribution system. This not only compromises the water quality but can also affect your health. So, what can you do? Do not make or allow improper connections at your homes. Even that unprotected garden hose lying in the puddle next to the driveway is a cross-connection. The unprotected lawn sprinkler system after you have fertilized or sprayed is also a cross-connection. When a cross-connection is allowed to exist at your home, it will likely affect you and your family first. If you would like to learn more about how to protect the quality of our water, contact us for information about ways you can help.

This report shows our water quality and what it means to you, our customer. If you have any questions or concerns about this report or your water utility, please contact Drew Hoffman or Derrick Rowberry at 801-785-2941. We want our valued customers to be informed about their water utility. If you would like to learn more, please attend any of our regularly scheduled meetings. They are held on the first and third Tuesday of each month, at 6:00 pm in the Community Room.

Pleasant Grove City routinely monitors contamination in our drinking water in accordance with the Federal and Utah State laws. The Safe Drinking Water Act defines the term "contaminant" as meaning any physical, chemical, biological, or radiological substance or matter in water. Therefore, the law defines "contaminant" very broadly as being anything other than water molecules. All sources of drinking water are subject to potential contamination by contaminates that are naturally occurring or manmade. Those contaminates can be microbes, organic or inorganic chemicals, or radioactive materials. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. Some drinking water contaminants may be harmful if consumed at certain levels in drinking water while others may be harmless. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

MCLs are set at very stringent levels. To understand the possible health effects described for many regulated contaminants, a person would have to drink two liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care providers about drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline at 1-800-426-4791.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Pleasant Grove City is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

In the following table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

**Non-Detects (ND)** - laboratory analysis indicates that the contaminant is not present.

**ND/Low - High** - For water systems that have multiple sources of water, the Utah Division of Drinking Water has given water systems the option of listing the test results of the contaminants in one table, instead of multiple tables. To accomplish this, the lowest and highest values detected in the multiple sources are recorded in the same space in the report table.

**Parts per million (ppm) or Milligrams per liter (mg/l)** - one part per million corresponds to one minute in two years or a single penny in \$10,000.

**Parts per billion (ppb) or Micrograms per liter (ug/l)** - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

**Parts per trillion (ppt) or Nanograms per liter (nanograms/l)** - one part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.

**Parts per quadrillion (ppq) or Picograms per liter (picograms/l)** - one part per quadrillion corresponds to one minute in 2,000,000,000 years or one penny in \$10,000,000,000,000.

**Picocuries per liter (pCi/L)** - picocuries per liter is a measure of the radioactivity in water.

**Millirems per year (mrem/yr)** - measure of radiation absorbed by the body.

**Million Fibers per Liter (MFL)** - million fibers per liter is a measure of the presence of asbestos fibers that are longer than 10 micrometers.

**Nephelometric Turbidity Unit (NTU)** - nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

**Action Level (AL)** - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Treatment Technique (TT)** - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

**Maximum Contaminant Level (MCL)** - The “Maximum Allowed” (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal (MCLG)** - The “Goal” (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Maximum Residual Disinfectant Level (MRDL)** - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG)** - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Date Sampled**- Because of required sampling time frames i.e. yearly, 3 years, 4 years and 6 years, sampling dates may seem outdated.

**Waivers (W)**- Because some chemicals are not used or stored in areas around drinking water sources, some water systems have been given waivers that exempt them from having to take certain chemical samples, these waivers are also tied to Drinking Water Source Protection Plans.

The following table shows the results of our monitoring for the period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2023.

TEST RESULTS							
Contaminant	Violation Y/N	Level Detected ND/Low-High	Unit Measurement	MCLG	MCL	Date Sampled	Likely Source of Contamination
<b>Microbiological Contaminants</b>							
Total Coliform Bacteria	N	ND	N/A	0	Presence of coliform bacteria in 5% of monthly samples	2023	Naturally present in the environment
Fecal coliform and <i>E.coli</i>	N	ND	N/A	0	If a routine sample and repeat sample are total coliform positive, and one is also fecal coliform or <i>E. coli</i> positive	2023	Human and animal fecal waste
Turbidity for Ground Water	N	ND-0.25	NTU	N/A	5	2022	Soil runoff
<b>Inorganic Contaminants</b>							
Barium	N	.02-.04	ppb	2000	2000	2022	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Carbon, Total Organic (TOC)	N	ND	ppm	NA	TT	2022	Naturally present in the environment
Copper a. 90% results b. # of sites that exceed the AL	N	a.110 b.0	ppb	1300	AL=1300	2022	Corrosion of household plumbing systems; erosion of natural deposits

Cyanide	N	2-7	ppb	200	200	2022	Discharge from steel/metal factories; discharge from plastic and fertilizer factories
Fluoride	N	ND-1	ppb	4000	4000	2022	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Lead a. 90% results b. # of sites that exceed the AL	N	a. 2 b.0	ppb	0	AL=15	2022	Corrosion of household plumbing systems, erosion of natural deposits
Nickel	N	ND-6	ppb	100	100	2022	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Nitrate (as Nitrogen)	N	ND-5	ppm	10	10	2023	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Selenium	N	2-7	ppb	50	50	2022	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
Sodium	N	2-24	ppm	None set by EPA	None set by EPA	2022	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills.
Sulfate	N	16-128	ppm	1000	1000	2022	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills, runoff from cropland
TDS (Total Dissolved solids)	N	164-396	ppm	2000	2000	2022	Erosion of natural deposits
<b>Disinfection By-products</b>							
TTHM (Total trihalomethanes)	N	ND-2	ppb	0	80	2023	By-product of drinking water disinfection
<b>Radioactive Contaminants</b>							
Alpha emitters	N	ND-5	pCi/1	0	15	2022	Erosion of natural deposits
Combined	N	1	pCi/1	0	5	2022	Erosion of natural deposits
Radium 226	N	0.64	pCi/1	0	5	2020	Erosion of natural deposits
Radium 228	N	-0.8-1	pCi/1	0	5	2022	Erosion of natural deposits

We at Pleasant Grove City work around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life, and our children's future.