



Annual Drinking Water Quality Report 2022

SAGINAW, TX

Annual Water Quality Report for the period of January 1 to December 31, 2022 This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water.

CITY OF SAGINAW water supply is Purchased Surface Water.

City Council Meets the 1st & 3rd Tuesday each month at 6:00 pm, discussion of water issues or concerns are welcome.

For more information regarding this report contact:
Jonathan D. Reames
at (817) 230-0553

Este reporte incluye información importante sobre el agua para tomar. Para asistencia en español, favor de llamar al telefono (817) 230-0553



INFORMATION ABOUT SOURCE WATER ASSESSMENTS

The TCEQ has completed a Source Water Assessment for all drinking water systems that own their sources. The report describes the susceptibility and types of constituents that may come into contact with your drinking water source based on human activities and natural conditions. The system(s) from which we purchase our water received the assessment report. For more information on source water assessments and protection efforts at our system, contact Jonathan D. Reames at (817) 230-0553.

For more information about your sources of water, please refer to the Source Water Assessment Viewer available at the following

URL: <http://www.tceq.texas.gov/gis/swaview>

Further details about sources and source-water assessments are available in Drinking Water Watch at the following URL: <http://dww2.tceq.texas.gov/DWW/>

The City of Saginaw purchases 100% of our drinking water from the City of Fort Worth. All treatment processes are completed by the City of Fort Worth at the treatment plant.

The City of Saginaw only monitors chlorine levels throughout our distribution system to ensure the residual never drops below the minimum of 0.5 mg/l. During the calendar year 2022 our average daily chlorine residual was 1.98 mg/L.

City of Saginaw Data for calendar year 2022

Disinfectant Residual Table

Disinfectant	Year	Average Level	Range of Levels Detected	MRDL	MRDLG	Unit of Measure	Violation (Y/N)	Likely Source of Contamination
Chloramines	2022	1.98 mg/L	0 - 5mg/L	4	4	mg/L	N	Water additive used to control microbes.

A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system. A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Coliform Bacteria

Maximum Contaminant Level Goal	Total Coliform Maximum Contaminant Level	Highest No. of Positive	Fecal Coliform or E. Coli Maximum Contaminant Level	Total No. of Positive E. Coli or Fecal Coliform Samples	Violation	Likely Source of Contamination
0	1 positive monthly sample.	3	0	0	N	Naturally present in the environment

Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, waterborn pathogens may be present or that a potential pathway exists through which contamination may enter the drinking water distribution system. We found coliforms indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessment(s) to identify problems and to correct any problems that were found during these assessments. During the past year we were required to conduct {ONE} Level 1 assessment. {ONE} Level 1 assessment was completed. In addition, we were required to take {ONE} corrective action and we completed {ONE} of these actions. During the past year {ONE} Level 2 assessment was required to be completed for our water system. {ONE} Level 2 assessment was completed. In addition, we were required to take {TWO} corrective actions and we completed {TWO} of these actions.

City of Saginaw Data: 2016 Regulated Contaminants Detected

Definitions: Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety. **Action Level:** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Lead	2022	0	15	1.7	0	ppb	N	Corrosion of household plumbing systems; Erosion of natural deposits.
Copper	2022	1.3	1.3	0.4789	0	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing.

Regulated Contaminants

Disinfectants and Disinfection By-Products	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Haloacetic Acids (HAA5)	2022	5	1.9 - 6.2	No goal for the total	60	ppb	N	By-product of drinking water disinfection.
Total Trihalomethanes (TTHM)	2022	5	2.49 - 5.98	No goal for the total	80	ppb	N	By-product of drinking water disinfection.
Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Nitrate [measured as Nitrogen]	2022	0.193	0.193 - 0.193	10	10	ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.

The Texas Water Development Board requires the City of Saginaw to conduct an annual water audit report. This report determines the amount of water loss that a system had throughout the year. The city submitted the 2022 report for the time period of January through December 2022. Our system lost an estimated 104,919,212 gallons of water. This loss is calculated by using events such as main breaks, theft, meter inaccuracies, Fire Department use and system maintenance. Using this data, the City of Saginaw had a 12% loss for the year. The city strives to have a 10% loss or lower on an annual basis. With better tracking methods, system inspections and monitoring, the city hopes to lower water loss each year. If you have any questions about the water audit, please call 817-230-0553..



DEFINITIONS

AL (Action Level): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

MRDL (Maximum Residual Disinfectant Level): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

MRDLG (Maximum Residual Disinfectant Level Goal): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

MCLG (Maximum Contaminant Level Goal): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

MCL (Maximum Contaminant Level): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

mg/L: Not defined here but is used in the report

NA: Not applicable

ND: Not detected

pCi/L: Not defined here but is used in the report

TT (Treatment Technique): A required process intended to reduce the level of a contaminant in drinking water.

ppm (parts per million): One part substance per million parts water (or milligrams per liter).

ppb (parts per billion): One part substance per billion parts water (or micrograms per liter).

NTU (Nephelometric Turbidity Units): Measurement of the clarity, or turbidity, of water.

WTP: Water Treatment Plant

TOC: Total Organic Carbon

HAA: Haloacetic Acids

TTHM: Total Trihalomethanes

LRAA: Local Running Annual Average

µmhos/cm: Not defined here but is used in the report

SOURCES OF DRINKING WATER

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.

Contaminants that may be present in source water include:

Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.

Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.

Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the system's business office.

You may be more vulnerable than the general population to certain microbial contaminants, such as Cryptosporidium, in drinking water. Infants, some elderly, or immuno-compromised persons such as those undergoing chemotherapy for cancer; persons who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders, can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care providers additional guidelines on appropriate means to lessen the risk of infection by Cryptosporidium are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.



Reporting UCMRS Results

Fort Worth started its UCMRS sampling in January 2023. We sampled at the distribution entry point for each treatment plant, except North Holly. North Holly was down at the time so its fourth quarter of sampling will occur in January 2024.

According to federal regulations, water systems must notify their customers of the results within 12 months of receiving the results and in the annual water quality reports. The 12-month time frame applies to the individual quarterly results.

Fort Worth plans to include the results of the January 2023 UCMR sampling in the annual water quality report it is now preparing. However, we have not yet received the data so cannot pass it along to you at this time. As soon as we receive it, we will send it to you.

If we do not include this results in this report, it would require a special mailing to customers to meet the 12-month notification requirement.



For more information on source water assessments and protection efforts at our system, contact Stacy Walters at 817-392-8203

Further details about the source-water assessments are available in the Texas Commission on Environmental Quality's Drinking Water Watch database.

http://dww2.tceq.texas.gov/DWW/JSP/SWAP.jsp?tinwsys_isnumber=5802&tinwsys_st_code=TX&wsnumber=TX2200012%20%20&DWWState=TX



City of Fort Worth Drinking Water Quality Test Results

Contaminant	Year Sampled	Measure	MCL	MCLG	Your Water	Range of Levels Detected	Violation	Likely Sources of Contaminant
Beta Particles & Photon emitters ¹	2021	pCi/L	50	0	7	7 to 7	No	Decay of natural and man-made deposits of certain minerals that are radioactive and may emit forms of radiation known as photons and beta radiation
Uranium	2021	mg/L	30	0	1.1	1.1 - 1.1	No	Erosion of natural deposits
Arsenic	2022	ppb	10	0	1.7	0 - 1.7	No	Erosion of natural deposits; runoff from orchards, runoff from glass and electronics production wastes
Atrazine	2022	ppb	3	3	0.1	0 - 0.1	No	Runoff from herbicide used on row crops
Barium	2022	ppm	2	2	0.08	0.04 to 0.08	No	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Chromium	2022	ppb	100	100	2.8	0 - 2.8	No	Erosion of natural deposits; discharge from steel and pulp mills
Cyanide	2022	ppb	200	200	51	0 to 51	No	Discharge from plastic and fertilizer factories; discharge from steel/metal factories
Fluoride	2022	ppm	4	4	0.64	0.18 - 0.64	No	Water additive that promotes strong teeth; erosion of natural deposits; discharge from fertilizer and aluminum factories
Nitrate (measured as Nitrogen)	2022	ppm	10	10	0.57	0.13 - 0.57	No	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Bromate	2022	ppb	10	0	5.81	0 - 137	No	By-product of drinking water disinfection
Haloacetic Acids	2022	ppb	60	N/A	7.98	2.2 to 7.4	No	By-product of drinking water disinfection
Total Trihalomethanes	2022	ppb	80	N/A	13.9	0 to 17.3	No	By-product of drinking water disinfection

Contaminant	Year Sampled	Measure	MCL	MCLG	Highest / Average Level Detected	Range of Levels Detected	Violation	Likely Sources of Contaminant
Turbidity ²	2022	NTU	TT = 1.0	N/A	0.7	N/A	No	Soil Runoff (Turbidity is a measure of the cloudiness of water. It is monitored because it is a good indicator of the effectiveness of the filtration system.)
			TT = Lowest monthly % of samples ≤ 0.3 NTU		99.3%			

Compound	Year Sampled	Measure	MCL	MCLG	High	Low	Average	Violation	Likely Sources of Contaminant
Total Organic Carbon ³	2022	ppm	TT = % Removal	N/A	1	1	1	No	Naturally occurring

It is used to determine disinfection by-product precursors. Fort Worth was in compliance with all monitoring and treatment technique requirements for disinfection by-product precursors. A removal ratio of 1 in SUVA calculations is considered passing.

Contaminant	Year Sampled	Measure	MRDL	MRDLG	Your Water	Range of Levels Detected	Violation	Likely Sources of Contaminant
Chloramines ⁴	2022	ppm	4.0	4.0	3.4	1.4 to 4.3	No	Water additive to control microbes

Contaminant	Year Sampled	MCL	Your Water	Range of Levels Detected	Violation	Likely Sources of Contaminant
Total Coliform (including fecal coliform & E. Coli)	2022	TT = 5.0% of monthly samples are positive	2.4%	0 - 2.4%	No	Coliforms are naturally present in the environment as well as feces; fecal coliform and E. coli only come from human and animal fecal waste

Unregulated Contaminants⁶

Compound	Measure	MRDL	MRDLG	Average	Range of Detect	Common Sources of Substance in Drinking Water
Bromoform	ppb	NOT REGULATED	0	0.62	0 - 3.24	By-product of drinking water disinfection; not regulated individually; included in Total Trihalomethanes
Bromodichloromethane	ppb	NOT REGULATED	0	2.93	3.41 - 5.43	
Chloroform	ppb	NOT REGULATED	70	2.45	3.74 - 5.71	
Dibromochloromethane	ppb	NOT REGULATED	60	2.41	1.96 - 5.9	By-product of drinking water disinfection; not regulated individually; included in Haloacetic Acids
Dibromoacetic Acid	ppb	NOT REGULATED	NA	1.24	1.40 - 2.90	
Dichloroacetic Acid	ppb	NOT REGULATED	0	3.47	4.50 - 5.60	
Monobromoacetic Acid	ppb	NOT REGULATED	NA	0	0 - 0	
Monochloroacetic Acid	ppb	NOT REGULATED	70	0.02	0 - 1	
Trichloroacetic Acid	ppb	NOT REGULATED	20	0	0 - 0	

Microorganism testing shows low detections in raw water

Tarrant Regional Water District monitors the raw water at all intake sites for Cryptosporidium, Giardia Lamblia and viruses. The source is human and animal fecal waste in the watershed.

The 2022 sampling showed occasional low level detections of Cryptosporidium and Giardia Lamblia in some but not all of the water supply sources. No viruses were detected.

Cryptosporidium and Giardia Lamblia are removed through disinfection and/or filtration.

CORROSION CONTROL: To meet requirements of the Lead and Copper Rule, Fort Worth achieves corrosion control through pH adjustment.

TCEQ assesses raw water supplies for susceptibility

Fort Worth uses surface water from Lake Worth, Eagle Mountain Lake, Lake Bridgeport, Richland Chambers Reservoir, Cedar Creek Reservoir, Lake Benbrook and the Clear Fork Trinity River.

Fort Worth owns Lake Worth. The U.S. Army Corps of Engineers is responsible for Benbrook Lake. The other four lakes are owned and operated by Tarrant Regional Water District.

The Texas Commission on Environmental Quality completed an assessment of Fort Worth's source waters. TCEQ classified the risk to our source waters as high for most contaminants.

High susceptibility means there are activities near the source water or watershed that make it very likely that chemical constituents may come into contact with the source water. It does not mean that there are any health risks present. Tarrant Regional Water District, from which Fort Worth purchases its water, received the assessment reports.

For more information on source water assessments and protection efforts at our system, contact Stacy Walters at 817-392-8203.

Further details about the source-water assessments are available in the Texas Commission on Environmental Quality's Drinking Water Watch database at http://dww2.tceq.texas.gov/DWW/JSP/SWAP.jsp?tinwsys_is_number=5802&tinwsys_st_code=TX&wnumber=TX2200012%20%20%20%20%&DWWSTATE=TX.

Secondary Constituents

These items do not relate to public health but rather to the aesthetic effects. These items are often important to the industry.

Item	Measure	Your Water
Bicarbonate	ppm	87.6 - 144
Calcium	ppm	33.6 - 51.9
Chloride	ppm	20.9 - 47.0
Conductivity	µmhos/cm	310 - 475
pH	units	8.1 - 8.5
Magnesium	ppm	3.95 - 10
Sodium	ppm	25 - 35
Sulfate	ppm	26 - 41.6
Total Alkalinity as CaCO3	ppm	90.4 - 144
Total Dissolved Solids	ppm	161 - 278
Total Hardness as CaCO3	ppm	100 - 171
Total Hardness in Grains	Grains/Gallon	6 - 11