



| METER VAULT VALVE AND FITTING SCHEDULE |  |            |       |
|--|--|------------|-------|
| NO.                                    | DESCRIPTION  | SIZE       | JOINT |
| 1.                                     | ASTM D2737 CTS HDPE POLY PIPE (BLUE) W/TRACER WIRE   | 1.5" OR 2" | COMP. |
| 2.                                     | FORD SERIES 70 COPPER SETTER (H=21"), WITH BALL VALVE INLET & ASSE APPROVED ANGLE DUAL CHECK VALVE OUTLET AND STANDARD BYPASS & CARTRIDGE DUAL CHECK VALVE (2" MODEL VBHC74-21W-11-44-NL) (1 1/2" MODEL VBHC76-21B-11-66-NL) (OR APPROVED EQUAL) | 1.5" OR 2" | FLG   |
| 3.                                     | COMPOUND METER (SENSUS OMNI C <sup>2</sup> RADIO READ FURNISHED & INSTALLED BY CITY)   | 1.5" OR 2" | FLG   |
| 4.                                     | OUTLET LINE AS PER PLAN  | 1.5" OR 2" | -     |
| 5.                                     | BRASS BALL VALVE (MUELLER 300 BALL)  | 1.5" OR 2" | -     |

NOTE: PROVIDE GRIP JOINT FOR COPPER OR PLASTIC TUBE AS NEEDED. THE METER SETTER SHALL BE NO SMALLER IN SIZE THAN THE LATERAL FROM THE MAIN TO THE METER SETTER INSTALLED.

- NOTES:
1. FOR EXISTING LINE, CONTRACTOR SHALL POT HOLE EXISTING PIPE TO VERIFY DEPTH & SHALL ADJUST BOX DEPTH ACCORDINGLY.
  2. CONTRACTOR SHALL RESTORE ALL SURFACE IMPROVEMENTS TO PRE-CONSTRUCTION CONDITION WHERE REQUIRED.
  2. PROVIDE ANY ADDITIONAL PIPE & FITTINGS AS NECESSARY.